Ref. Certif. No.

HU-004542

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	PV DC surge protector device
Name and address of the applicant	Zhejiang ETEK Electrical Technology Co.,Ltd. NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang P.R. China
Name and address of the manufacturer	Zhejiang ETEK Electrical Technology Co.,Ltd. NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang P.R. China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Zhejiang ETEK Electrical Technology Co.,Ltd. NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang P.R. China
Ratings and principal characteristics	Ucpv:1000VDC;In:20kA;Imax:40kA; Up:4.0kV;Iscpv:30A;Indoor;One port; Itotal:40kA;Class II
Trademark / Brand (if any)	ETEK(logo)
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	EKU5-T2-40PV-3M1000,CAU5-T2-40PV-3M1000 EKU5-T2-40PV-3M1000S,CAU5-T2-40PV-3M1000S
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 61643-31:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	CN23SPZC 001

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-08-16

Signature: Wencai Zhang

10/061SMD 2022-07 rke-fix

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.29 / 0)